

KENYA BIOVAX INSTITUTE LIMITED

P.O BOX 40779-00100

TEL: +254775751639

Email: procurement@biovax.go.ke / info@biovax.go.ke

Website: www.biovax.go.ke

23rd January 2024

RE: ADDENDUM NO. 1

TENDER NO. KBI/IFT/OIT/001/2023-2024, DESIGN, BUILD, ASSEMBLE, INSTALL, COMMISSION, TRAINING AND MAINTENANCE OF ENABLING WORKS OF A GMP-CERTIFIED, 'FILL – AND – FINISH', TURN-KEY STERILE BIOMANUFACTURING FACILITY.

1.0 Addendum No. 1 herein has made correction to the closing date which now is **16th February 2024** at 11.00am East African Time and the Title which now includes '**Install**' and also pre-bid conference to be held on **23rd January 2024** from **10.00am to 12.30pm** at BioVax offices at Embakasi and **30th January 2024** from **10.00 am up to 12.30pm**.

2.0 In addition, the following contact number has been provided to allow for ease of communication **+254 775 751 639**

3.0 Further additional email address has also been provided as info@biovax.go.ke for communication purposes.

4.0 Additional information has also been provided on treated water storage tanks as follows: -

Pursuant to **PART II – PROCURING ENTITY'S INFRASTRUCTURAL FACILITY REQUIREMENTS** clause **2.4.1**, part **j** of the tender document, the procuring Entity hereby issues the following clarifications: -

Treated water storage tanks details are as follows:

A) SECTION 1-MATERIAL SPECIFICATIONS.

- Hot rolled sections to BS 4360 Grade 43A or equivalent.
- Cold formed sections to BS 5950 Part 5: 1997 or equivalent.
- Bolt and nuts to BS 3692 and BS 4190 or equivalent.
- Welding specifications to BS 5135 or equivalent.
- Welding electrodes to BS 635 or equivalent.
- Wind load to CP3 chapter V part 2.

B) SECTION 2 – TANK DETAILS

Pressed steel tanks out of embossed **mild** steel plates complete with roof cover, internal bracings, internal and external ladder, water level indicator, vent, cleats, stays, manhole with lockable cover, glastichord jointing compound, galvanized nuts, bolts, and washers.

NB:

Plate thickness for the tank is 4.5mm

Tank Capacity is 4m×4m×3m (48 m³).

10 Meters Structural steel work for the tower to support 48m³ tank (when full of water) comprising of tower SHS columns, angle bracings, platform beams, access cat ladder and fixtures necessary for erection. The tower is painted with one coat of grey oxide primer and one coat of silver aluminum paint.

C) SECTION 3 – FOUNDATION DETAILS

Foundation for the 10m tower [1:2:4] concrete and reinforcement, depth of bases not less than 1,000 mm

The other terms and conditions remain the same as per the bid document

ADDENDUM SUMMARY TABLE

NO.	CLAUSE/ITEM REFERENCE	ORIGINAL VERSION	ADDENDUM	AFFECTED REFERENCE / PAGE NO.
1.	Tender Name and Description	Design, Build, Assemble, Commission, Training And Maintenance Of Enabling Works Of A Gmp-Certified, 'Fill – And – Finish', Turn-Key Sterile Biomanufacturing Facility	Design, Build, Assemble, Install , Commission, Training And Maintenance Of Enabling Works Of A Gmp-Certified, 'Fill – And – Finish', Turn-Key Sterile Biomanufacturing Facility	1. Newspaper advert on the Daily Nation of 17 th January 2024 2. Cover page of Bid document
2.	Closing Date and Time	6 th February 2024	16th February 2024	1. Newspaper advert on the Daily Nation of 17 th January 2024 2. Bid Document pages; ix, 19, 20, 21, 28 (item no.13)
3.	Pre-Bid Conference	NB: PRE-BID CONFERENCE SHALL BE HELD ON 23 RD JANUARY 2024 AND SITE VISIT CERTIFICATE ISSUED	NB: PRE-BID CONFERENCE SHALL BE HELD ON 23 RD JANUARY 2024 (FROM 10.00AM UP TO 12.30PM EAST AFRICAN TIME) AND ON 30TH JANUARY 2024 FROM 10.00AM UP TO 12.30PM EAST AFRICAN	1. Newspaper advert on the Daily Nation of 17 th January 2024 2. Bid Document

			TIME AT BIOVAX PREMISES – EMBAKASI AND A SITE VISIT CERTIFICATE ISSUED.	pages; 19 (ITT 8.1)
4.	Email Address	procurement@biovax.go.ke	procurement@biovax.go.ke / info@biovax.go.ke	1. Bid Document pages; x, 19, 22
5.	Cell Phone Number	Not Available	+254 775 751 639	1. Bid Document pages; x, 19, 20
6.	Treated water storage tanks with adequate capacity	Specification Missing	Details Highlighted in Part No. 4.0 above of addendum	1. Bid Document Clause 2.4.1 part J (page; 76)